

**STATEMENT OF BASIS**  
**CITY OF CASTLE ROCK**  
**NPDES PERMIT NO. WA0022683**

The purpose of this Statement of Basis is to explain the need to modify the Permit to add conditional language for total residual chlorine limit due to the facility installing UV.

**I. GENERAL INFORMATION**

- A.     Permittee:                   City of Castle Rock  
  P.O. Box 370  
  Castle Rock, WA 98611
- B.     Discharge Locations:   Cowlitz River  
  Latitude: 46° 16' 02" N  
  Longitude: 122° 54' 26" W

**II. REQUEST FOR MODIFICATION:**

The facility has gone through construction and upgrades and have put a UV system into their plant, eliminating the need for chlorine.

In Special Condition S1 of the permit, the following language was added to the total chlorine residual limit:

This effluent limit applies whenever chlorine is used in the facility. If no chlorine is used during the monitoring period enter "no discharge of chlorine" on the DMR for the period.

This Statement of Basis will serve as an amendment to the Fact Sheet and Permit.